



TEST CERTIFICATE

CLADDING SMITHS CO.

Rainscreen Cladding System

Test Laboratory	Test Facilities Limited
Tested To	CWCT Standard for Systemised Building Envelopes, 2006
Test Date	1 February 2024 to 5 February 2024
Clauses Tested	Clause 5 – Wind resistance. Satisfactory Clause 9 – Water tightness (dynamic) Satisfactory Clause 10 – Impact resistance. Satisfactory Clause 11 – Foot traffic

The rainscreen cladding system was tested in accordance with the CWCT Standard for Systemised Building Envelopes. Detail results are in Test Report No. 95321

Authorised Signatory

The Centre for Window & Cladding Technology